(ENGINEERS)



SUBMITTAL DATA

Metal Building Roof Curbs

Model: UMB-3	Additional Options:		
Metal Building Roof Curb for Under/Under Roof Installation.	1.		
Standard Construction:	2.		


Standard Construction:


One-piece curb with 18 ga. Galvalume steel shell and baseplate; 8" minimum height, cricket water diverter, insulated, internal angle reinforcing with mitered corners and watertight welds; no rib closures, prime painted after fabrication.


3.

4.

Roof Panel Manufacturer: _____Type: _____







SECTION "A-A" UMB-3 NON-INSULATED

No. Req'd.	I.D.		O.D.				DEV DATE
					DRAWN BY: SRB	DATE: 4-26-06	REV. DATE: 1-4-11
Tag- Description		Н		L	DEV / NO	4 DDD 0) (ED D) (DIAGO NIO
					REV. NO.	APPROVED BY: CBY	DWG. NO.: M-25